

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**

Product  
Produit

Switching Adaptor

Name and address of the applicant  
Nom et adresse du demandeur

KEEN OCEAN INDUSTRIAL LTD  
ROOM 3405, 34TH FL  
CABLE TV TOWER  
9 HOI SHING RD  
TSUEN WAN, N T, Hong Kong

Name and address of the manufacturer  
Nom et adresse du fabricant

KEEN OCEAN INDUSTRIAL LTD  
ROOM 3405, 34TH FL  
CABLE TV TOWER  
9 HOI SHING RD  
TSUEN WAN, N T, Hong Kong

Name and address of the factory  
Nom et adresse de l'usine

HE YUAN SKY WEALTH ELECTRONIC AND PLASTIC CO LTD  
HI-TECH DEVELOPMENT ZONE HEYUAN GUANGDONG  
517000  
CHINA

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page

Additional Information on page 2

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales

Input 100 - 240 Vac, 50/60 Hz, 0.40 A max.

Output : 3-24 Vdc, 100-2500 mA max.

Trademark (if any)  
Marque de fabrique (si elle existe)

See Enclosure Miscellaneous ID7-01 in the test report for details.  
Keen Ocean Industrial Ltd

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais  
constructeur

S02-012-YYYY-ZZZZZ Series  
See Page 2

Model / Type Ref.  
Ref. De type

Additional information (if necessary may also be  
reported on page 2)  
Les informations complémentaires (si nécessaire,,  
peuvent être indiqués sur la 2<sup>ème</sup> page

Additionally evaluated to EN 60950-1:2006 /A11:2009 /A1:2010  
/A12:2011; National Differences specified in the CB Test Report.

Additional Information on page 2

A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 60950-1(ed.2), IEC 60950-1(ed.2);am1

As shown in the Test Report Ref. No. which forms  
part of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

E317501-A5-CB-2 issued on 2013-02-22

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2013-02-22

Signature:

Jan-Erik Storgaard



Ref. Certif. No.

**DK-31183-UL**

**Model Details:**

S02-012-YYYY-ZZZZZ Series (Where YYYY can be ranged from 0030 to 0240 represent output voltage (e.g. 0030 = 3.0V); ZZZZZ can be ranged from 00100 to 02500 represent output current (e.g. 00100 = 100mA))

**Additional Information:**

See illustration ID 7-01 in the test report for model number nomenclature.

**Additional information (if necessary)**

**Information complémentaire (si nécessaire)**



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see [www.ul.com/ncbnames](http://www.ul.com/ncbnames)

Date: 2013-02-22

Signature:

Jan-Erik Storgaard